



Report No: - C &I/ 250172

Date: -09.05.2025

TEST REPORT

Name of Customer	M/s. Career Point Gurukul School Near New Bus Stand, Raipura Road, Thegda, Kota
Reference No.	Letter, Date: - 07.05.2025
Lab. Job No.	250172
Sample Receipt Date	08.05.2025
Name of Work	-----
Material/ Material Identification	Water Sample
Make/Source	R.O. water
Date of Testing	09.05.2025

Discipline: Chemical Testing

Group: Water

TEST RESULTS

S.No.	Parameters	Results	Requirment (Acceptable) Limits As per IS 10500-2012 RA 2018 (Max. Limits)	Test Method
1.	pH Value @25°C	7.39	6.5-8.5	IS-3025-P(11):1983
2.	Turbidity (NTU)	1.0	1.0	IS-3025-P(10):1982
3.	Taste	Agreeable	Agreeable	IS-3025-P(8):1984
4.	Colour (Hazen)	1.0	5	IS-3025-P(4):1987
5.	Odour	Agreeable	Agreeable	IS-3025-P(5):1983
6.	Total Dissolved Solids (mg/l)	92	500	IS-3025-P(16):1984
7.	Total Hardness (as CaCO ₃) (mg/l)	75	200	IS-3025-P(21):2009
8.	Acidity (mg/l)	Nil	---	IS-3025-P(22):1986
9.	Alkalinity (as CaCO ₃) (mg/l)	25	200	IS-3025-P(23):1986
10.	Chloride (as Cl), (mg/l)	49.9	250	IS-3025-P(32):1988
11.	Sulphate (as SO ₄), (mg/l)	66.0	200	IS-3025-P(24):1986
12.	Calcium (as Ca), (mg/l)	16.0	75	IS-3025-P(40):1991
13.	Magnesium (as Mg), (mg/l)	6.08	30	IS-3025-P(46):1994

Checked by: 

Note: -

1. The test result refers only to the samples received in the Laboratory.
2. This report shall not be reproduced except in full without written approval from C&I SYSTEMS Laboratory.
3. Any discrepancy in test results should be reported within 15 days from the date of report.
4. C&I SYSTEMS Laboratory shall not in any way be involved in any action following the interpretation of test results.
5. This report is not valid for any Legal proceeding.

End of Report

Page 1 of 1



Authorized Signatory: 